

C.NO.98/ADV/CFO/HBL/2024

To,  
The Principal  
Shri Shankarling Model School  
Chikkalgud, Hukkeri Taluk  
Belagavi District

Sir,

Sub : Issue of 'Fire safety recommendation/Advice' to Shri Shankarling Model School at Chikkalgud Village, Hukkeri Taluk, Belagavi District.

Ref : 1) Applicants request letter dated 01/07/2024  
2) C.No.09/DFO/Belagavi/2024 Dated 13/07/2024

\_\*\_\*\_\*\_\*\_\*\_\*\_\*\_\*\_

With reference to the subject above cited, the premises of Shri Shankarling Model School building consisting with ground floor + 1 upper floor situated at Chikkalgud Village, Hukkeri Taluk, Belagavi District was inspected by the District Fire Officer, Belagavi on 08/07/2024 with respect to Fire prevention, Fire fighting and Evacuation measures to be complied in the above premises and has submitted the details as under.

**ANNEXURE-1**

**(Up to 14.99 mtrs. in height)**

**Group B Education Building**

*NBC-2016, Part-4, Table 7 (11) 3.1.3 Group B Educational Buildings sub division B1& B2.*

**(These condition are indicative and not exclusive all relevant provisions related to fire and life safety of NBC 2016 are mandatory)**

**A. Details of the building / premises :-**

01	Name and Address of the Applicant.	:	The Principal Shri Shankarling Model School Chikkalgud, Hukkeri Taluk Belagavi District
02	Name and Address of the premises.	:	Shri Shankarling Model School Chikkalgud, Hukkeri Taluk Belagavi District
03	Name and address of the Building owner	:	The Principal Shri Shankarling Model School Chikkalgud, Hukkeri Taluk Belagavi District



04	Number of buildings	:	01
05	Number of floors	:	Ground Floor + 1 Upper Floor
06	<b><u>Floor-wise details of occupancy:-</u></b>		
	Ground floor	:	16 nos. of Class Room, 02 nos. of Computer Lab, Science Lab, Staff Room, Chairman Cabin, Office Room, Principle Cabin.
	First floor	:	18 nos. of Class Room, Library, Hall
07	Height of the building	:	07.80 Mtrs.
08	Site area	:	32,071.33 Sq. Mtrs.
09	<b>Built-up area of each floor:-</b>		
	Ground floor	:	3,644.01 Sq. Mtrs.
	First floor	:	3,644.01 Sq. Mtrs.
10.	<b>Total built-up area</b>	:	<b>7288.02 Sq. Mtrs.</b>
11.	<b>Surrounding properties:-</b>		
	East	:	Approach Road
	West	:	Open Land
	North	:	Open Land
	South	:	Open Land
12.	<b><u>Set-back area available around the building :-</u></b>		
	East	:	05.00 Mtr
	West	:	05.00 Mtr
	North	:	05.00 Mtr
	South	:	05.00 Mtr
<b>Allowed setbacks (open space) should be maintained free from further obstruction / construction</b>			

**Note :** Recommended to provide and maintain setbacks as per Local ZR.

**B. On inspection of this Educational premises, the following fire prevention, fire fighting and evacuation measures recommended are considered absolutely essential from fire safety point of view :**

Sl. No. (1)	Details (02)	Existing (03)	Recommendations (04)
01.	Accessibility to the premises	The Premises is Abutting from Eastern Side By P.B Road.	Adequate
02.	No. of entrances	01 no. of entry & 04 nos. of exit.	Recommended to provide at least 1 entry & 1 exit.



03.	Width of entry / exit	Entry 07.90 mtrs	Adequate Minimum 06.00 mtrs. width with height clearance of minimum 05.00 mtrs. from ground level.	
04.	Diesel generators.	---	Recommended to provide Diesel Generator of 30 KVA capacity.	
05.	No. of staircases available	Nos. of staircases	: 04	Adequate Recommended to provide staircases maintaining travel distance with 22.50 mtrs. with minimum 02.00 mtrs. width, 30 mm treads width, 15 mm treads height, 1 mtr. Handrail, with minimum 02.20 head room clearance.
		Width of staircases	: 1.50 mt	
		Width of treads	: 30 cm	
		Height of risers	: 14 cm	
		Nos. of riser per flight	: 11	
		Height of handrails	: 0.30 mt	
		Head room clearance	: 3.60 mt	
06.	No. lifts and capacity.	Nos. of lifts	: --	N/A
		Capacity of lifts	: --	
07.	Fire extinguisher	Provided 04 nos. of ABC type fire Extinguisher of 05 kg capacity.	<p>A. One water mist extinguisher of 9 ltrs capacity should kept near each staircase landing.</p> <p>B. One mechanical foam extinguisher of 9 ltrs. capacity &amp; One ABC type extinguisher of 6 kgs. capacity should be provided near diesel generator.</p> <p>C. One CO2 type fire extinguisher, of 4.5 kgs. capacity should be provided near each electrical panel board &amp; electrical room.</p> <p>D. One ABC type fire extinguisher of 06 kgs</p>	





			at the entrance/security room.
14.	Escape routes	---	Recommended to Provide Direction in which the employees/ Students should have to move in the event of any emergency have been marked with luminous paint at each floor directing the employees towards emergency exits.
15.	Fire order	---	Fire safety plans has to be indicated with details of actions to be taken in case of an emergency near staircase landings at each floor with telephone numbers of Hukkeri fire station i.e., <b>8762862101 &amp; 101</b> telephone numbers of the nearest Ambulance service & Police Station.
16.	No smoking board	---	COPTA Sec-4 direction No Smoking area smoking here is an offence board should be written in English & Kannada both language shall be prominently displayed at inside the entry/exit of the each floor.
17.	Fire fighting training	---	At-least 40% of employees shall be got trained in basic fire fighting at R.A.Mundkur fire & Emergency Services Academy, Bannerughatta road, Bangalore within 3 months or at an early date. And shall be submitted to this office.



18. Fire precautionary measures:-
- Explosive and flammable materials should not be stored in the store room, UPS room, Electrical panel area, class rooms, laboratory & electrical sum panel premises.
  - Accumulation of combustible waste in and around the premises should be avoided.
  - The exit ways shall be always kept clear without any obstruction.
  - Liquefied petroleum gas should not be stored in the building.
  - The doors shall not be kept locked/latched during working hours and shall be free from obstruction.
  - During the class hours the class room doors shall not be locked from inside to outside.
  - As per Hon'ble supreme court order all teachers and staffs shall be trained to handle safety equipment, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the Fire Safety Day on April 14<sup>th</sup> of every year by conducting Fire Safety drills with co-ordinate with fire service department.

The Karnataka Fire & Emergency Service Department is issued the Fire Safety recommendations in compliance to the undersigned, within 90 days.

**All requirements recommended above are as per National Building Code-2016 Part-4 clause 3.1.4 of Fire and Life safety will have to be complied with mandatorily.**

From the above details it is clear that the '**Management**' of the above Educational building have been recommended to provide fire precautionary measures as per **National Building Code 2016, Part-4, Table 7 (11) 3.1.3 Group B Educational Buildings Sub division B1 & B2**. After full-filling the above recommendations, a Certificate should be obtained by this office. ***If at any time any of the conditions are found not complied with, this Certificate shall stand withdrawn/cancelled.***


Hence, On the report submitted by the District Fire Officer Belagavi this recommendation certificate is issued to Shri Shankarling Model School building consisting with ground floor + 1 upper floor situated at Chikkalgud Village, Hukkeri Taluk, Belagavi District.

This certificate is valid for a period of one year from the date of issue of this letter and is renewable.



Copy to the District Fire Officer Belagavi.

Yours faithfully,

  
**CHIEF FIRE OFFICER**  
 Karnataka State Fire and  
 Emergency Services, Hubballi Zone  
 HUBBALLI-25

20/7/2024